

**CHANGES TO VOLUME I  
FIRE CODE**

**Definitions Page.**

**STATE OF ARKANSAS  
ARKANSAS FIRE PREVENTION CODE RULES**

**2007 EDITION**

These Rules are promulgated by the Director of the Department of Arkansas State Police, who serves by operation of law as the Arkansas State Fire Marshal under the authority granted by Arkansas Act 254 of 1955, codified at A.C.A. §§ 12-13-101 to A.C.A. §12-13-116, as amended. The purpose of these Rules is to aid in the implementation, interpretation, and enforcement of the Arkansas Fire Prevention Code (AFPC), 2007 Edition.

The International Fire Code, 2006 Edition, the International Building Code, 2006 Edition, and the International Residential Code, 2006 Edition, as published by the International Code Council and the rules, as amended and adopted by the Arkansas State Fire Marshal, shall constitute the Arkansas Fire Prevention Code, 2007 Edition. These Rules shall be effective [August 1, 2008](#).

The following shall be defined as:

INTERNATIONAL PLUMBING CODE shall mean the Arkansas State Plumbing Code.

INTERNATIONAL PRIVATE SEWAGE DISPOSAL CODE is replaced by “Arkansas Department of Health Rules Pertaining to Onsite Wastewater Systems”.

INTERNATIONAL MECHANICAL CODE shall mean the Arkansas State Mechanical Code.

INTERNATIONAL FUEL GAS CODE shall mean the Arkansas State Gas Code.

INTERNATIONAL ENERGY CONSERVATION CODE shall mean the Arkansas Energy Code.

INTERNATIONAL FIRE CODE shall mean the Arkansas Fire Prevention Code, Volume I.

INTERNATIONAL BUILDING CODE shall mean the Arkansas Fire Prevention Code, Volume II.

INTERNATIONAL RESIDENTIAL CODE shall mean the Arkansas Fire Prevention Code, Volume III.

INTERNATIONAL ELECTRICAL CODE shall mean the Arkansas (National) Electrical Code.

BUILDING OFFICIAL shall mean any governmental official having authority to enforce that aspect of the Code.

Dotted lines in the margin indicate Arkansas revisions.

Solid Stars in the margin indicate Arkansas deletions.

## **Chapter 1, Administration**

**101.1 Title.** These rules shall be known as the *Arkansas Fire Prevention Code*.

**101.2.1 Appendices.** Provisions in the appendices shall not apply unless specifically adopted. Appendices B, C, D, E, F, and G are adopted by the State of Arkansas. Other appendices shall not apply unless adopted by local ordinance. Requests for exceptions to Appendix D may be appealed to the Arkansas State Fire Marshal (State Fire Marshal).

**101.2.2 Locally Adopted Codes.** Each district, county, municipality or other political subdivision of this state shall only adopt and enforce the provisions of the Arkansas Fire Prevention Code, 2007 Edition. The AFPC 2007 Edition shall be the only foundation document available for modification by local jurisdictions should they choose to adopt more stringent provisions. It shall be the responsibility of local authorities having jurisdiction to bring the proposed specific rule or provision up to the minimum standards of the AFPC 2007 Edition. The State Fire Marshal shall advise local jurisdictions of any requirement that is less stringent than the AFPC 2007 Edition.

**102.3 Change of use or occupancy.** No change shall be made in the use or occupancy of any structure that would place the structure in a different division of the same group or occupancy or in a different group of occupancies, unless such structure is made to comply with the requirements of this Code and the *Arkansas Fire Prevention Code Volume II*. Subject to the approval of the fire code official, the use or occupancy of an existing structure shall be allowed to be changed and the structure is allowed to be occupied for purposes in other groups without conforming to all the requirements of this Code and the *Arkansas Fire Prevention Code Volume II* for those groups, provided the new or proposed use is less hazardous, based on life and fire risks, than the existing use.

**102.4 Application of building code.** The design and construction of new structures shall comply with the *Arkansas Fire Prevention Code Volume II*, and any alterations, additions, changes in use or changes in structures required by this Code, which are within the scope of the *Arkansas Fire Prevention Code Volume II*, shall be made in accordance therewith.

## **102.10 MEMORANDUM OF UNDERSTANDING-HEALTH CARE FACILITIES.**

This Memorandum of Understanding will specify and serve as a method to resolve conflicts between the Arkansas Fire Prevention Code Rules, **2007 Edition** (hereinafter “Arkansas Fire Prevention Code” or “AFPC”) adopted and enforced by the Arkansas State Fire Marshal’s Office, under the authority of the Director of the Department of the Arkansas State Police, and other federal or state rules governing Arkansas’ health care and long-term care facilities, by law regulated by the Arkansas Department of Health and the Arkansas Department of Human Services, Division of Medical Services, Office of Long-Term Care, among others.

1. The Arkansas Department of Health and the Arkansas Department of Human Services, Division of Medical Services, Office of Long-Term Care will have inspectors and/or plan reviewers obtain training related to the implementation and application of the National Fire Protection Association Life Safety Code (NFPA 101) and the Arkansas Fire Prevention Code.
2. The Arkansas Department of Health will have concurrent authority to do Fire and Life Safety Code inspections in health care facilities regulated by the Arkansas Department of Health. The Arkansas Department of Human Services, Division of Medical Services, Office of Long-Term Care, will have concurrent authority to do Fire and Life Safety inspections in long-term care facilities regulated by the Arkansas Department of Human Services, Division of Medical Services, Office of Long-Term Care. The Arkansas Department of Health’s authority and the authority of the Arkansas Department of Human Services, Division of Medical Services, Office of Long-Term Care will be concurrent with the current authority of any other relevant federal, state or local government agency having authority to do said inspections.
3. The Arkansas Fire Prevention Code is the fire prevention code for the State of Arkansas.
4. When there is a conflict between the Arkansas Fire Prevention Code and the National Fire Protection Association Life Safety Code (NFPA 101), New Health Care Occupancies Chapter, Existing Health Care Occupancies Chapter, New Ambulatory Health Care Occupancies Chapter, and Existing Ambulatory Health Care Occupancies Chapter, as adopted by the United States Department of Health and Human Services, Centers for Medicare Medicaid Services, per Title 42 Code of Federal Regulations, the aforementioned chapters in the Life Safety Code shall govern.
5. For new construction, when one of the affected agencies (Arkansas Department of Health, Arkansas Department of Human Services, Division of Medical Services, Office of Long-Term Care, local fire official, or local building official) determines or perceives that a conflict exists between the Arkansas Fire Prevention Code and the National Fire Protection Association Life Safety Code (NFPA 101), as it relates to types of construction or allowable area requirements,

they shall provide written notification of the perceived conflict to the project architect or engineer and the other affected agencies. The agency alleging the conflict will convene a meeting with the other affected agencies to resolve the conflict. The resolution of the conflict must be unanimous. If the group is unable to resolve the conflict unanimously, the issue will be referred to the Arkansas State Fire Marshal for final resolution.

Agreed to as evidenced by the signatures of the participating Parties for their respective offices or associations below:

Arkansas State Fire Marshal, and Director of Arkansas State Police or his designee  
**Colonel Winford E. Phillips, Director of Department of Arkansas State Police; and Lt. Lindsey Williams, Arkansas State Fire Marshal**

Arkansas Hospital Association  
**Mr. Phil E. Matthews, President and Chief Operating Officer**

Arkansas Department of Health  
**Dr. Paul Halverson, Director and State Health Officer**

Arkansas Department of Human Services  
**Mr. John Selig, Director, Arkansas DHS**

Arkansas Fire Chiefs' Association  
**Chief George Glenn**

Arkansas Fire Marshals' Association  
**Fire Marshal Travis Hollis**

Code Officials of Arkansas Chapter of International Code Council ("ICC")  
**Mr. Wally Bailey**

#### **104.3.2 State Fire Marshal jurisdiction.**

(a) The State Fire Marshal's Office has statewide jurisdiction to inspect all places in Arkansas insofar as it is necessary for the enforcement of all laws, ordinance and law, or ordinances and lawful orders requiring any place to be safe from fire. The State Fire Marshal or his/her duly authorized representative(s) shall be charged with the enforcement of this Code as granted under the authority of Act 254 of 1955, as amended.

(b) The fire official shall have primary responsibility for the safety of places in his/her own district, city or county. Rules of the State Fire Marshal's Office establishing minimum standards, shall not prevent any district, city or county from enacting more stringent regulations; and the State Fire Marshal's Office shall cooperate with the fire official in enforcing all fire safety laws and ordinances of the state or its political

subdivisions. Inspections of property in the territory served by the fire department shall be made as often as practicable or as often as the city or county legislative body or other political subdivision fire officials may direct.

(c) A written report of continued violations should be sent to the State Fire Marshal, who will cooperate with local authorities to secure compliance with the *Arkansas Fire Prevention Code* and other laws, ordinances and rules of the state and its political subdivisions relating to matters within the scope and jurisdiction of the State Fire Marshal's Office.

(d) **Town, City or County Building Officials:** when a jurisdiction establishes a building department and a building official as set out in Vol. II, Section 103 of the Code, the primary responsibility for administering and enforcing Vol. II (Building Code) of the AFPC shall fall to that established administrative authority.

**104.10.2 Report of fire fatalities.** Fire departments responding to fires resulting in a fatal injury shall report in writing such fatalities to the State Fire Marshal's Office within 3 business days of the occurrence.

**104.10.3 Fire reports submitted to Arkansas Fire Academy.** Fire departments responding to fires within their jurisdiction shall, by the 15<sup>th</sup> of the month following the occurrence of the fire, furnish to the Arkansas Fire Academy (AFA) for the National Incident Fire Reporting System (NFIRS), information about the fire, on forms provided by and approved by the Arkansas Fire Academy.

**104.10.4 Changes in fire department information.** All fire departments shall submit on or before June 30<sup>th</sup> of each year the name of the officer in charge, the mailing address and electronic mailing address, telephone and facsimile numbers of the fire department and other information to the State Fire Marshal's Office on a form provided by the State Fire Marshal's Office. Any change in the pertinent information during the year shall be sent to the State Fire Marshal's Office in writing no later than thirty (30) days after the change occurs.

**104.10.5 Reports of fireworks accidents.** Accidents involving fireworks resulting in death, serious injury, or major property damage shall be reported immediately to the State Fire Marshal's Office by the responding fire or police department or the holder of a fireworks license or public display permit.

**105.1 General. Fireworks licenses or public display permits.** Permits shall be obtained as required below. Such permits will be issued when the requirements of the State Fire Marshal's office have been met; and they may be suspended or revoked if the requirements are violated. Application for "State Permits" required as follows, shall be made in writing, on forms required, to the State Fire Marshal, Arkansas State Police, 1 State Police Plaza Drive, Little Rock, AR 72209-2971. The State Fire Marshal's Office telephone number is 501-618-8624 until further notice.

1. **Fees.** No fee is required for a state fireworks license or public display permit except as prescribed for licenses relating to fireworks and except as hereafter otherwise provided by law and these rules.

2. **State Permits.** A permit or license shall be obtained from the State Fire Marshal for:

- (a) Dealing in fireworks as set out in state fireworks laws;
- (b) Public fireworks display permit for indoor and outdoor displays; and
- (c) Installation of aboveground storage tanks for combustible liquids, flammable liquids, and hazardous chemicals.

3. **Local Permits.** Where provisions are made by a municipality or county or other political subdivision of the state for the issuance of permits, and where such rules are at least as stringent as those of the State Fire Marshal, a permit from an authorized city or county official or other political subdivision official shall be obtained for the construction or substantial remodeling of any:

- (a) Asylums, hospitals, nursing or convalescent homes, or other health care facilities, regardless of capacity.
- (b) Schools and educational institutions having a capacity in excess of 50 pupils, and residence buildings, including dormitories, having sleeping accommodations for 50 or more persons.
- (c) Auditoriums, theaters, indoor stadiums, gymnasiums, churches, or other places of assembly having a capacity in excess of 100 or more persons.
- (d) Department stores or factories having a capacity in excess of 200 persons or for any other building if located within the city or county fire service jurisdiction or other political subdivision. A city, county, or other political subdivision of the state may, by ordinance, set out other permits that may be required for new or existing structures.

4. **Building Permits.** Where a jurisdiction has established a building department in accordance with Vol. II, Section 103 of the Code, permits within the corporate limits of the jurisdiction for new construction or remodeling shall be required in accordance with Vol. II, Section 105 of the Code.

**108.1 Board of appeals established.** Any county or municipality or other political subdivision may establish a local board of adjustments and appeals, to review orders given by the local fire official; and to consist of 5 members appointed by the applicable governing body.

**109.3 Violation penalties.** Persons who shall violate a provision of this Code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter, repair or do work in violation of the approved construction documents or directive of the fire code official, or of a permit or certificate used under provisions of this Code, shall be guilty of a Class A Misdemeanor, punishable by a fine of not more than \$1,000.00 dollars or by imprisonment not exceeding 1 year, or both such fine and imprisonment. Each day that a violation continues after due notice has been served shall be deemed a separate offense.

**111.4 Failure to comply.** Any person who or other legal entity (corporation, limited liability company, limited liability partnership, etc.) which shall continue any work after having been served with a stop work order, except such work as that person or entity is directed to perform to remove a violation or unsafe condition, shall be subject to penalties imposed by the circuit or district court having jurisdiction.

## **Chapter 2, Definitions.**

**[B] Educational Group E.** Educational Group E occupancy includes, among others, the use of a building or structure, or a portion thereof, by six or more persons at any one time for educational purposes through the 12<sup>th</sup> grade. Religious educational rooms and religious auditoriums, which are accessory to places of religious worship in accordance with Section 508.3.1 of the *Arkansas Fire Prevention Code, Volume II* and have occupant loads of less than 100, shall be classified as Group A-3 occupancies.

**Day care.** The use of a building or structure, or portion thereof, for educational, supervision or personal care services for more than 5 children older than 2 ½ years of age shall be classified as an “E” occupancy. Day Care (Child Care) Facilities shall meet the provisions of NFPA 101, the Arkansas Fire Prevention Code, and the following:

1. Day care facilities that are licensed (or making application for a license) to have 16 or fewer children shall follow the guidelines for Day Care Homes as set out in NFPA 101, 2003 Edition.
2. Day care facilities that are licensed (or making application for a license) to have 17 children or more shall follow the guidelines for day care centers as set out in NFPA 101, 2003 Edition.
3. The staff-to-client ratios referred to in Chapters 16 and 17, NFPA 101, are amended to follow the ratios adopted by the Arkansas Department of Human Services, Division of Child Care and Early Childhood Education, Child Care Licensing (telephone 501-682-8590 until further notice):
  - A. Child Care Centers, 2006;
  - B. Day Care Family Homes, 2006; and
  - C. Minimum Licensing Standard for Child Welfare Agencies, 2006. (This includes Residential Care Child Care Facilities, Emergency Residential Child Care Facilities, Psychiatric Residential Treatment Facilities, and Sexual Offender Programs).
4. The fire authority retains the authority to enforce the more stringent ratio if it is determined the facility needs the more stringent ratios in order to assure fast and safe evacuation of the facility in an emergency for life safety.

**Group I-4, day care facilities.** This group shall include buildings and structures occupied by persons of any age who receive custodial care for less than 24 hours by individuals other than parents or guardians, relatives by blood or marriage or adoption, and in a place other than the home of the person cared for. A facility such as the above with 5 or fewer persons shall be classified as Group R-3 or shall comply with the *Arkansas Fire Prevention Code, Volume III* in accordance with Section 101.2 of the *Arkansas Fire Prevention Code, Volume II*. Places of worship during religious functions are not included.

**Adult care facility.** A facility that provides accommodations for less than 24 hours for more than 5 unrelated adults and provides supervision and personal care services shall be classified as Group I-4.

**Exception:** Where the occupants are capable of responding to an emergency situation without physical assistance from the staff, the facility shall be classified as Group A-3.

**Child care facility.** A facility that provides supervision and personal care on less than a 24 hour basis for more than 5 children 2 ½ years of age or less shall be classified as Group I-4.

**Exception:** A child day care facility which provides care for more than 5 but no more than 100 children 2 ½ years or less of age, when the rooms where such children are cared for are located on the level of exit discharge and each of these child care rooms has an exit door directly to the exterior, shall be classified as Group “E”.

**Exception:** The definition of Day Care occupancies shall meet the provisions of the Arkansas Fire Prevention Code and NFPA 101, 2003 Edition. The definitions of day care occupancies as set out in NFPA 101, 2003 Edition shall be amended in accordance with any future changes per Department of Human Services Division of Child Care capacities.

<u>Number of Occupants</u>	<u>Usage</u>
Less than 6 6, but less than 11	R-3 Occupancy Family Day Care Home, NFPA 101, 2003 Edition
11, but less than 17	Group Day Care Home, NFPA 101, 2003 Edition
More than 16, but less than 100	Day Care Occupancy, NFPA 101, 2003 Edition
Any usage 100 or more	Group “E” or “I” Occupancy

**Chapter 3, General Precautions Against Fire**

**303.10** At the end of day or work period, the roof work shall be scanned (checked) with a heat source meter or electronic scanner to determine any hot spots on wood curbs, cants, or roof projections on the completed roof which could smolder or combust after workers leave the job. An acceptable alternative to scanning the roof is to monitor the roof for three (3) hours’ minimum before workers leave the job site.

**Chapter 4, Emergency Planning And Preparedness** No changes

**Chapter 5, Fire Service Features** No changes

**Chapter 6, Building Services And Systems** No changes

**Chapter 7, Fire-Resistance-Rated Construction** No changes

**Chapter 8, Interior Finish, Decorative Materials And Furnishings** No changes

**Chapter 9, Fire Protection Systems**

**906.1 Where required.** Portable fire extinguishers shall be installed in the following locations:

1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies.  
*[Former exception to 906.1, Item 1, has been deleted]*

**912.2.3 Proximity to hydrant.** Fire department connections for each sprinkler system or standpipe system shall be located not more than 100 feet from the nearest fire hydrant connected to an approved water supply.

**Chapter 10, Means Of Egress**

**1001.1 General.** Buildings or portions thereof shall be provided with a means of egress system as required by this chapter. The provisions of this chapter shall control the design, construction, and arrangement of means of egress components required to provide an approved means of egress from structures and portions thereof. Sections 1003 through 1026 shall apply to new construction. Sections 1027 and 1028 shall apply to existing buildings.

**Exception:** 1. Detached one- and two-family dwellings and multiple single-family dwellings (townhouses) not more than 3 stories above grade plane in height with a separate means of egress and accessory structures shall comply with the *International Residential Code*.

2. Residential Care/Assisted Living Occupancies. Existing residential care/assisted living occupancies shall comply with the existing board and care requirements of NFPA 101, 2003 Edition and the Child Welfare Agency Review Board of the Arkansas Department of Health and Human Services.

**Chapter 11, Aviation Facilities** No changes

**Chapter 12, Dry Cleaning** No changes

**Chapter 13, Combustible Dust-Producing Operations** No changes

**Chapter 14, Fire Safety During Construction And Demolition** No changes

**Chapter 15, Flammable Finishes** No changes

**Chapter 16, Fruit And Crop Ripening** No changes

**Chapter 17, Fumigation And Thermal Insecticidal Fogging** No changes

**Chapter 18, Semiconductor Fabrication Facilities** No changes

**Chapter 19, Lumber Yards And Woodworking Facilities** No changes

**Chapter 20, Manufacture Of Organic Coatings** No changes

**Chapter 21, Industrial Ovens** No changes

**Chapter 22, Motor Fuel-Dispensing Facilities and Repair Garages**

**2201.1 Scope.** Automotive motor fuel-dispensing facilities, marine motor fuel-dispensing facilities, fleet vehicle motor fuel-dispensing facilities and repair garages shall be in accordance with this chapter and the *Arkansas Fire Prevention Code, Vol. II, Arkansas Gas Code*, and the *Arkansas Mechanical Code*. These facilities shall include both public and private operations.-

**2204.3 Unattended self-service motor fuel dispensing facilities.** Unattended self-service motor fuel-dispensing facilities shall comply with Sections 2204.3.1 through 2204.3.7. This section shall not apply to unattended fleet vehicle service stations as defined in Section 2202.1. All unattended (new and existing) self-service stations shall only be installed or continue service after having met the minimum guidelines and a permit issued by the State Fire Marshal with concurrence of the local building and fire official. Applications for an unattended self-service station shall be on a form provided by the State Fire Marshal.

**2204.3.6 Fire Suppression.** A fixed fire suppression system or approved sprinkler system shall be installed under the canopy and around the dispensing unit in accordance with NFPA 13, 17, 17A, or an equivalent system approved by the State Fire Marshal. Automatic fire (heat) detection shall be installed under the canopy per NFPA 72. A manual fire alarm station(s) per NFPA 72 shall be installed. The area around the parking space shall be such that it will have a catch basin to the side capable of preventing the runoff of spilled flammable liquids, and shall be approved by the authority having jurisdiction.

**2204.3.7 Quantity limits.** Dispensing equipment used at unsupervised locations shall comply with 1 of the following:

1. Dispensing devices shall be programmed or set to limit uninterrupted fuel delivery to 35 gallons (133 Liters) for cars, pickups, vans, and similar small vehicles; and 100 gallons per transaction at facilities serving large trucks and requiring a manual action to resume delivery.

2. The amount of fuel being dispensed shall be limited in quantity by a preprogrammed card as approved.

**2206.2.1.1 Inventory control for underground tanks. [Deleted in its entirety]**

**2206.2.3 Above-ground tanks located outside, above grade.** Above-ground tanks shall not be used for the storage of Class I, II or IIIA liquid motor fuels except as provided by this section.

1. Above-ground tanks used for outside, above-grade storage of Class I liquids shall be designed, constructed, and maintained in accordance with 1 or more of the following nationally recognized engineering standards and be in accordance with Chapter 34. Such tanks shall be located in accordance with Table 2206.2.3.
  - A. Atmospheric tanks: API Standard 650, API Specifications 12B, 12D or 12F, UL 80, UL 142, UL 2080 or UL 2085.
  - B. Low-pressure tanks: ASME Boiler and Pressure Vessel Code, Section VIII or API Standard 620.
  - C. Pressure Vessels: ASME Boiler and Pressure Vessel Code, Section VIII.
2. Above-ground tanks used for above-grade storage of Class II or IIIA liquids are allowed to be protected above-ground tanks or, when approved by the fire code official, other above-ground tanks that comply with Chapter 34. Tank locations shall be in accordance with Table 2206.2.3.
3. Tanks containing fuels shall not exceed 12,000 gallons (45 420 L) in individual capacity or 48,000 gallons (181 680 L) in aggregate capacity. Installations with the maximum allowable aggregate capacity shall be separated from other such installations by not less than 100 feet (30, 480 millimeters).
4. Tanks located at farms, construction projects, or rural areas shall comply with Section 3406.2.

**Chapter 23, High-Piled Combustible Storage** No changes

**Chapter 24, Tents, Canopies, And Other Membrane Structures** No changes

**Chapter 25, Tire Rebuilding And Tire Storage** No changes

**Chapter 26, Welding And Other Hot Work** No changes

**Chapter 27, Hazardous Materials—General Provisions** No changes

**Chapter 28, Aerosols** No changes

**Chapter 29, Combustible Fibers** No changes

**Chapter 30, Compressed Gases** No changes

**Chapter 31, Corrosive Materials** No changes

**Chapter 32, Cryogenic Fluids** No changes

**Chapter 33, Explosives And Fireworks** No changes

**Chapter 34, Flammable and Combustible Liquids**

**3404.2.13.2.2 Out of service for 90 days.** Above-ground tanks not used for a period of 90 days shall be safeguarded in accordance with Section 3404.2.13.1.2 or removed in accordance with Section 3404.2.14.

**Exceptions:**

1. Tanks and containers connected to oil burners that are not in use during the warm season of the year or are used as a backup heating system to gas;
2. In-place, active fire protection (foam) system lines; and
3. Farm tanks used for irrigation wells or other farm uses.

**Chapter 35, Flammable Gases** No changes

**Chapter 36, Flammable Solids** No changes

**Chapter 37, Highly Toxic And Toxic Materials** No changes

**Chapter 38, Liquefied Petroleum Gases** Delete this chapter in its entirety. Refer instead to the Arkansas Liquefied Petroleum Gas Code.

**Chapter 39, Organic Peroxides** No changes

**Chapter 40, Oxidizers** No changes

**Chapter 41, Pyrophoric Materials** No changes

**Chapter 42, Pyroxylin (Cellulose Nitrate) Plastics** No changes

**Chapter 43, Unstable (Reactive) Materials** No changes

**Chapter 44, Water-Reactive Solids And Liquids** No changes

**Chapter 45, Referenced Standards** No changes

**Appendix A Board Of Appeals** Delete in its entirety

**Appendix B Fire-Flow Requirements For Buildings** No changes

**Appendix C Fire Hydrant Locations And Distribution** No changes

**Appendix D Fire Apparatus Access Roads**

**D101.1 Scope.** Fire apparatus access roads shall be in accordance with this appendix and all other applicable requirements of the *Arkansas Fire Prevention Code, Volume I*. Requests for exceptions to Appendix D may be appealed to the State Fire Marshal.

**Appendix E Hazard Categories** No changes

**Appendix F Hazard Ranking** No changes

**Appendix G Cryogenic Fluids—Weight And Volume Equivalents** No changes

**Index** No changes