

City of Fayetteville Building Safety Division

POLICY & PROCEDURE


Auxiliary Condensate Drain and Pan

AMC 307.2.3 requires one of the following where damage may occur if the main condensate drain becomes clogged:

1. An auxiliary pan with a separate drain.
2. If it is not possible to install a pan then the auxiliary (secondary) drain on the unit must be piped to an obvious point.
3. An auxiliary pan with an overflow switch that will shut off the unit.

As an alternative to #2, an overflow switch may be installed at the secondary drain if it not possible to install the secondary drain line.

Approved By



Building Official