

# City of Fayetteville Building Safety Division

## POLICY & PROCEDURE

### Electrical Pedestals

Electrical pedestals with disconnects shall be considered connection points only purposes of interpreting the Electrical Code.

This means that the point of service will be where the conductors from the pedestal are connected to main disconnect on or at the buildings. These service conductors shall be sized per the NEC based on the main disconnect at the building. Grounding shall be at the building served and not connected to the ground in the pedestal.

Pedestals require inspection and approval for temporary or permanent service.

Approved By



\_\_\_\_\_  
Building Official