

City of Fayetteville Building Safety Division

POLICY & PROCEDURE

Existing Meter – Lights Out

An electrical permit and inspection are required before a meter installation will be approved when repairing existing services if new conductors, conduit, and/or connections are used.

A service mast served overhead by the utility company may be reattached to the building without permit and inspection. The service mast will meet the serving utility company requirements for supporting the overhead service drop.

Inspections may be made before permits are obtained in lights-out situations. The utility company may reconnect a service after work hours of the City and advise the Building Safety Division the next working day for inspections in lights-out situations.

Approved By



Building Official

January 11, 2001