

City of Fayetteville Building Safety Division

POLICY & PROCEDURE

Main Disconnect Identification

Permanent stick-on identification will be required on three or more grouped electrical mains before a meter will be approved for the power company to install. The apartment or suite number shall be permanently identified and attached to each main disconnect at the meter location with a minimum of one inch markings. Identification with paint, rite-on and magic markers will not be approved.

Approved By



Building Official

April 29, 2002