

Bid 08-54, Addendum 1



Date: Monday, August 04, 2008

To: All Prospective Vendors

From: Andrea Foren, CPPB – 479.575.8220 – aforen@ci.fayetteville.ar.us

RE: Bid 08-54, College Avenue Lighting Construction

This addendum is hereby made a part of the contract documents to the same extent as though it were originally included therein. Bidders should indicate their receipt of same in the appropriate blank of the Form of Proposal. Failure to do so may subject bidder to disqualification. Addendum shall be attached to the inside cover of the bidding documents, signed, and dated.

- **Bid 08-54, has the following modifications and clarifications:**

- 1.) FOB Destination for all lighting unit components shall be 1525 South Happy Hollow Road, Fayetteville, AR 72701.
- 2.) All anchor bolts shall be included as part of the lighting units.
- 3.) **Bids will be awarded based** on the lowest responsive responsible bidder according to price given for Item "A" on bid form. Item A is the total turn-key bid amount (which includes the lighting units). Bid award shall be based off of Item A unless the deductive alternate has to be subtracted to get the project within certification of funds.
- 4.) The required bid bond shall be 5% of "Item A – Total Turn-Key Bid Amount" (including the purchase of all lights) and shall be submitted with all bids.
- 5.) The footings shall be completed by the City of Fayetteville. The pole base shall be included as part of the "Lighting Unit".
- 6.) Contractor shall have 10 working days from date of notice to proceed to begin work on the section indicated in such notice to proceed. The City reserves the right to issue notice to proceed documentation as sections are completed along College Avenue and become ready for lighting installation.
- 7.) The City is willing to issue an initial primary payment to the contractor for stored materials purchased for this project.
- 8.) Conduit installed is 1 inch. The plans show an inaccurate figure of 3/4 inch.

9.) Modify Section 16510 - Lighting Fixtures as follows:

- Modify 1.05 Special Warranty (B) to include the following: The contractor shall furnish installation for any defective lighting units that fail within 12 months after project final completion. In the event the contractor provides the lighting units to the City, they will also be responsible for replacement of complete lighting unit, including but not limited to pole base, pole, lamp, ballast, & fuses.
- Modify Section 1.06 Extra Materials: Replace quantity of 100 to 70. Extra materials will therefore, read as follows:
 - 1. Lamps: 5 for each 70 of each type and rating installed
 - 2. Ballasts: 1 for each 70 of each type and rating installed
 - 3. Glass or plastic lenses and covers: 1 for each 70 of each type and rating installed.

10.) The City anticipates awarding a contract on the September 2nd City Council Meeting. A notice of award should be issued by Tuesday, September 9th at which time contractor can order materials for entire job.

Acknowledge Addendum #1:
Printed Name: _____
Signature: _____
Title: _____ Date: _____
Company: _____